

AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE OF PAGES	
					1 1	
2. AMENDMENT/MODIFICATION NO.		3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.
A001		See Item 16C.		PR9814249		
6. ISSUED BY			7. ADMINISTERED BY		CODE	
Procurement/Contracting Office U.S. Embassy 1-10-5 Akasaka Minato-ku, Tokyo 107-8420 Japan			See Item 6.			
8. NAME AND ADDRESS OF CONTRACTOR				9a. AMENDMENT OF SOLICITATION NO.		
				√		
				19JA80-21-Q-0001		
				9b. DATED (SEE ITEM 11)		
				April 20, 2021		
				10a. MODIFICATION OF CONTRACT/ORDER NO.		
				10b. DATED (SEE ITEM 13)		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<p><input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation, or as amended, by one of the following methods:</p> <p>(a) by completing Items 8 and 15 and returning one copy of the amendment;</p> <p>(b) by acknowledging receipt of this amendment on each copy of the offer submitted; or</p> <p>(c) by separate letter or telegram which includes a reference to the solicitation and amendment numbers.</p> <p>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</p> <p>If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment and is received prior to the opening hour and date specified.</p>						
12. ACCOUNTING AND APPROPRIATION DATA						
N/A						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS; IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER:						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return <u>one</u> copy to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION						
Request for Quotations (RFQ) No. 19JA80-21-Q-0001, Fan Coil Pipe Insulation Replacement Services, is hereby amended as follows:						
Delete Pages 12 and 14 under Section C: Description/Specifications/Statement of Work of RFQ in their entirety and replace with the attached revised Pages 12 and 14 and add Page 14-a, effective the date of the Contracting Officer's signature.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remain unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER				16A. NAME OF CONTRACTING OFFICER		
Type or print				Darin A. Phaovisaid		
15B. NAME OF CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
BY				BY		4/26/2021
(signature of person authorized to sign)				(signature of Contracting Officer)		



Photo 3: Case 1

Part of the drywall from the top of the FCU and on both sides shall be replaced. Molds shall be removed and clean using proper chemical on the unreplaced part. The contractor shall restore with the same thickness of new drywall ~~and apply finishing putty work~~. All glass wool insulation used for pipes shall conform to JIS A 9504 with aluminum foil faced vapor barrier (JIS A 9501). No ~~putty and~~ painting work needed. The contractor shall complete the work in 1 working day. Approximately 14X12mm of drywall shall be cut and restored.

2) **Case 2:** The branch supply and return pipes insulation inside the FCU shall be replace with Armaflex insulation and/or double layered glass wool insulation for tight spaces. The new insulation shall be cover with plastic sheets and taped properly to avoid condensation water leaking to the floor. Wool glass insulation shall be installed /filled inside the FCU. The aqua switch/thermocouple device shall be move from after the 2-way valve to before the 2-way valve. All glass wool insulation used for pipes shall conform to JIS A 9504 with aluminum foil faced vapor barrier (JIS A 9501). The contractor shall complete the work in 1 working day.

3) **Case 3:** The contractor shall replace bad horizontal and vertical chilled water pipe insulation in other pipe shafts, pipes that runs behind the wall and ceilings like those connected to air purge valves, FCU in the dining room, sleeping bedrooms and other pipes supplying water to wall type FCU. This work includes sealing all gaps around the area (minimum of 11 locations shall be opened and sealed) and application of wool insulation material and/or dry boards partitions if necessary. The contractor shall carefully wrap the insulation with plastic especially on the connection point between the old insulation and the new insulation. The case 4 shall be calculated in per meter length basis including both for replacement of insulation and drywall. The contractor shall complete the work in 3 working days.



Photo 6: Case 3

3) **Case 4:** The contractor shall replace horizontal and vertical pipes found to be in bad condition after the removal of insulation. The scope of work shall be calculated in per meter length basis. Pipe size is 50mm diameter in maximum and made of Steel Galvanized Pipe (SGP). The contractor shall complete the work in 2 working days. Leak check, including enough and proper air purge and flushing of the rusty chips & water shall be performed accordingly upon completion of the installation.

Case 3: Additional Pictures





